



Session 1C: The Impact of Make-Up Air Velocities on Atrium Smoke Control

The primary purpose of this study was to develop engineering methods to assess the impact of increased make-up air velocity in atria. The current restriction defined by NFPA 92 states that make-up air must not exceed 1.02 m/s (200 fpm) during the operation of a mechanical smoke exhaust system. This limitation not only limits creative and aesthetic atria designs but may also represent a significant cost. The present study analyzed the effect of make-up air injected by a variety of vent sizes at elevations at or below the limiting elevation of the flame through numerical simulations. This study focused on identifying worst-case scenarios for the interaction of make-up air with an axisymmetric plume, by modeling multiple configurations, observing the results, and adapting further simulations to elicit the most extreme cases. A mass flow rate diagnostic is used to assess the increase in entrainment, i.e. smoke production. This mass flow diagnostic is developed to provide a comparative analysis, assessing the increase in the rate of smoke production with a specified make-up air velocity with that produced with no mechanical make-up air. The proportional increase in entrainment is defined as an alpha factor. The most significant smoke production increase and smoke layer stabilization descent is associated with the 1 MW fire, when lesser increases observed for the 2.5 MW and 5 MW fires. As the make-up air is introduced further from the edge of the flame, the apparent effect of the airflow velocity is reduced.



Jim Milke, PhD, P.E.
Professor and Chair
Department of Fire Protection Engineering
University of Maryland
College Park, MD

James A. Milke, P.E., is a Professor and Chair of the Department of Fire Protection Engineering at the University of Maryland. He received his Ph.D. in Aerospace Engineering, a M.S. degree in Mechanical Engineering, and a B.S. degree in Fire Protection Engineering from the University of Maryland. In addition, he has earned a B.S. degree in Physics from Ursinus College. Dr. Milke has served as a Research Fire Prevention Engineer at the Building and Fire Research Laboratory, National Institute of Standards and Technology, and as a Fire Protection Engineer for Fairfax County, Virginia.

Dr. Milke is a Fellow of the Society of Fire Protection Engineers and a past president. He is also a member of the National Fire Protection Association, as well as the UL Fire Council, and the International Association of Fire Safety Science.

WWW.SFPEATLANTA.ORG

Please visit the website for conference costs and registration information.